

F-GAS CERTIFICATE

Leak detector verification certificate according EN 14624

PANIMPEX NV



We certify that the refrigerant leak detectors,
D-TEK Select, Compass and TEK-Mate, developed and produced by

INFICON Inc.,
2 Technology Place,
East-Syracuse, NY 13057,
USA

are in accordance with the devices tested by the

Centre d'Energétique
60, boulevard Saint-Michel
75272 PARIS Cedex 06

following the procedure of the EN 14624 Standard.
(see end of this journal for complete text)

The sensitivity measured by the 'Centre d'Energétique' is:

| | D-TEK Select | Compass | TEK-Mate |
|-------------------------------|--------------|------------|------------|
| Sensitivity in fixed position | 1 gr/y | 1 - 2 gr/y | 1 - 2 gr/y |
| Sensitivity while moving | 1 gr/y | 1 - 2 gr/y | 1 - 2 gr/y |



JP Peirs - Panimpex NV
Veurnestraat 162
B-8660 De Panne
Belgium



- Verification of your leakdetector according to the EN 14624 F-GAS Standard.
- This certificate complies with the needs and demands of the F-GAS certification for professionals.
- This certificate is great added value for your customer. He will be able to verify that the maintenance done on his system is done properly.

- This service is available at your wholesaler and at Panimpex.

