

European Distribution



Slableedstraat 7
8630 Veurne
Belgium
Tel.: +32 58 421450
info@panimpex.com
www.panimpex.com



Danger

Super Seal 944KIT-947KIT-948KIT

Acute Tox. 4: H332 - Harmful if inhaled. Eye Dam. 1: H318 - Causes serious eye damage. Flam. Liq. 3: H226 - Flammable liquid and vapour. Skin Sens. 1B: H317 - May cause an allergic skin reaction. STOT RE 2: H373 - May cause damage to organs through prolonged or repeated exposure (Inhalation).

P210 Keep away from heat, hot surfaces, sparks, open flames and other ignition sources. No smoking. P280 Wear protective gloves/protective clothing/respiratory protection/eye protection/protective footwear. P302+P352 IF ON SKIN: Wash with plenty of water. P304+P340 IF INHALED: Remove person to fresh air and keep comfortable for breathing. P305+P351+P338 IF IN EYES: Rinse cautiously with water for several minutes. Remove contact lenses, if present and easy to do. Continue rinsing. P370+P378 In case of fire: Use Foam extinguisher (AB), Dry Chemical Powder (ABC) Fire Extinguisher, Carbon dioxide extinguisher (BC) to extinguish. P403+P235 Store in a well-ventilated place. Keep cool. P501 Dispose of contents/container in accordance with regulations on hazardous waste or packaging and packaging waste respectively.

Contains Trimethoxy(methyl)silane.

Substances that contribute to the classification: N-(3-(trimethoxysilyl)propyl)ethylenediamine; Trimethoxyvinylsilane

Panimpex NV
Slableedstraat 7
8630 VEURNE - Belgium
Phone: +32 58 421450
info@panimpex.com
www.panimpex.com

+32 58 42 14 50 Mon-Fri 9h-12h 14h-17h

Sealant

26/03/2024 4 UFI: 8XR2-S0FD-300U-YEJ9

SUPER SEAL 944KIT

Medium Systems

5-17 KW

Installation Instructions



www.panimpex.com

SUPER SEAL HVACR™

Super Seal is a light or low viscosity particle free liquid, that travels with the oil and refrigerant throughout the system. When a leak is detected Super Seal forms a low tensile crystalline structure, at point of leakage, when activated by moisture from the surrounding air.

Installation Instructions - Professional Formula For Residential Systems 5 kW up to 17 kW

- For professional use only: Always wear safety glasses and protective gloves
- Do not use on mobile systems, ask for Super Seal Premium™ or Super Seal Pro™
- Use in compliance with the Montreal Protocol and Regional or Federal laws for the handling of refrigerant


Important before proceeding:

You should not be losing more than 14% of the entire refrigerant charge over a 4 week period to have maximum results with Super Seal. Sealant should only be injected into a refrigeration system that is moisture and contaminate free, as this could cause premature compressor failure. Before installing Super Seal HVACR™ check the overall condition of the unit. The system should be operating within its approximate normal pressure/ temperature conditions. Check the compressor by taking a temperature reading at its base. Readings above 54°C may indicate a line restriction or low oil/refrigerant charge. Failure to replace a contaminated or plugged filter drier may result in compressor failure. Where there is the possibility of refrigerant contamination an acid/ moisture test should be performed and followed up with recommended clean up procedure. If the system has to be evacuated it is advisable to change both liquid and suction line driers and to obtain a minimum of 350 microns or less to eliminate moisture and non-condensable. Charge to factory required levels.

INSTRUCTIONS: clock wise = cw and counter clockwise = ccw.

Install into a fully charged system

1. Turn off A/C unit and allow enough time for refrigerant to equalize in system.
2. Confirm that can tapper piercing pin (B) is fully retracted below seating washer. Turn valve handle (A) ccw.
3. Thread Super Seal HVACR™ can (C) onto can-tapper (B) by turning cw. Be careful not to cross thread or over tighten.
4. Thread female fitting (D) onto vacuum pump and draw vacuum for approximately 1 minute to eliminate air in tap hose. (Where Regional and Federal laws permit you may use systems refrigerant to purge air from hose.)
5. Remove female fitting (D) from vacuum pump while it is running to maintain vacuum in tap hose. After disconnecting shut down vacuum pump.
6. Thread female fitting (D) onto low side service port immediately after removing from vacuum pump.
7. Turn can-tapper piercing handle (A) cw until it stops. This action pierces the can.
8. Hold can upside down and above the low side service port. Turn handle (A) ccw slowly allowing the system's refrigerant to fully charge can. The can will become warm once the refrigerant mixes with its contents. Allow the can to dissipate the additional heat of charging which should take between 5 to 10 minutes depending on systems charge and ambient air conditions. When the can's temperature has equalized with ambient air conditions then proceed



with next step. Be sure to check that all connections from can to unit are secure and that there is no leakage occurring.

9. Turn handle (A) cw until it stops, isolating charged can from A/C or R unit.

10. While holding the can upside down, turn on A/C or R unit. Slowly turn handle (A) ccw gradually releasing sealant into the system. This should take approximately 3 to 5 minutes. Releasing sealant too quickly could result in liquid slugging. Shake can gently to determine when empty. If all of the contents in can are not emptied after 5 minutes then turn can-tapper piercing handle (A) cw until it stops. Turn off A/C or R unit and repeat steps 8, 9 and 10 as many times as necessary to empty contents of can. This should dislodge any particles that may have entered the can from the refrigerant system. If this fails remove hose from low side service port, while A/C or R unit is on, and attach hose to refrigerant canister and charge can. Close valve CW and reattach can to low side of the A/C or R system. Proceed to step #6.

11. Once can is empty remove female fitting (D) from low side service port, then shut down A/C or R unit. Allow system's pressure to equalize. The A/C or R unit should be left off for approx. 5 minutes. This procedure allows product to mix with systems oil and when the unit is restarted will allow for equal distribution throughout system.

12. Reclaim residual refrigerant from can and hose using a recovery machine. Always purge recovery machine with dry nitrogen after reclaiming refrigerant from can and hose. When finished reclaiming refrigerant, dispose of can and hose.

Important before proceeding to use Super Seal HVACR™ with R410a systems:

The maximum allowable working pressure of the Super Seal can is 400 psig. Because of the higher-pressure characteristics of R 410a it is possible to exceed the can rating which could possibly lead to an accidental release of the product. The can has been fitted with a special safety relief valve, which will vent between 420 and 480 psig to prevent this from occurring. This is seen as an indent-curved arch on the bottom center of the can. As a safety precaution the R410a unit should have all refrigerant recovered. During this time it is highly recommended changing out the suction and liquid line driers. An evacuation of 350 microns or less should then be carried out. After this has been accomplished, proceed with the following steps.

INSTRUCTIONS: clock wise = cw and counter clockwise = ccw.

1. Confirm that can tapper piercing pin (B) is fully retracted below seating washer. Turn valve handle ccw.

2. Thread Super Seal can (C) onto can-tapper by turning cw. Be careful not to cross thread or over tighten.

3. Thread female fitting (D) onto vacuum pump and draw vacuum for approximately 1 minute to eliminate air in tap hose.

4. Remove female fitting (D) from vacuum while it is running to maintain vacuum in tap hose.

5. Thread female fitting (D) onto low side service port immediately after removing from vacuum pump.

6. With can and hose assembly attached to low side service port perform a second evacuation from the high side service port. Run the vacuum pump until you obtain 350 microns or less. Close your isolation valve on your vacuum pump and watch for any increases. If the pressure increases to 600 microns in less than one minute proceed to draw vacuum again down to 350 microns or less then continue on to next step. (Do not wait for increase of pressure.) Isolate gauges and vacuum pump from system using shut off valves. Do not disconnect.

7. Hold can upside down and above the low side port. Turn can- tapper piercing handle (A) cw until it stops. This action pierces the can.

8. Then turn handle ccw allowing product to flow from can to the unit.

9. Once can is emptied remove can and hose assembly from low-side charging port.

10. Proceed to carry out a third evacuation on the high side to remove any non-condensable, which may have entered the system during the installation of the sealant. This should only take between 3 to 5 minutes.

11. Recharge unit to manufacturer's specifications. Remove gauges after manufacturer's or original existing charge has been completed.

12. Turn unit on and perform system check to confirm that the unit is operating in peak performance using condenser and evaporator delta temperatures as a guideline. Allow the system to run for approximately 5 minutes and then shut down. A dwell period of another 5 minutes should allow for pressure equalization and excess sealant to migrate back to compressor oil sump. This operation is to allow for equal distribution of the sealant throughout the refrigeration system once it has been restarted.

13. The unit can now be started and follow its normal cycle of operation.

TAPPING VALVE AND HOSE NOT TO BE REUSED

NOTE: One 85ml can of Super Seal HVACR™ should only be used on units which contain a minimum refrigerant amount of 1,8 kg. and contain a minimum 890ml of oil capacity in compressor sump. Super Seal HVACR™ is to be used only on the low-pressure side of A/C or R unit. Can and hose must not be subject to pressures that exceed 20 bar working pressure.

Eye contact: Remove contact lenses and immediately flush eyes with water and continue washing for several minutes. Obtain medical attention.

Skin contact: Remove contaminated clothing. Wash with soap and water. If irritation persists or if contact has been prolonged, obtain medical attention.

Patent No. 6481221B2